

# **Dreissenid Mussel Control for Large Flow, Once-through Systems**

**Evaluation of Alternatives to Chlorine  
Tom Prescott PEng., RNT Consulting Inc.**

# **Most often used controls for mussels by facilities on the Great Lakes**

- Preventative chlorine application in the form of sodium hypochlorite for piping systems
- Periodic treatment with proprietary chemicals or chlorine for piping systems
- Mechanical cleaning for external structures

# **Why Consider Alternatives?**

- **Current chemical treatment methods have environmental risks**
- **Regulatory requirements for use of chemicals tend to be extensive**

# **Concurrent Evaluations of Promising Technologies by Ontario Power Generation**

- **Fine Pore Filtration**
- **UV Light**
- **Ozone - intermittent**
- **Ozone - continuous**

# Evaluation Pre-requisites

- Proven in lab or small scale pilots
- System-sized equipment available
- Evaluate efficacy, constructability, operability

# Filter

- Manufacturer – Kinetrics, Ontario
- 790 l/s (12,500 usgpm)
- 40 micron mesh
- automatic backwash
- Start-up November 15<sup>th</sup>, 1999

# Nanticoke GS on Lake Erie



# Site Selection Criteria

- Sufficient room for the large filter in the pumphouse
- Large variation in water quality at the site likely to challenge the filter
- Only 2 of the 3 service water pumps normally required in winter allowing for easier pump outages for installation and testing



# The System Arrangement

- Filter size - 6 feet in diameter, 12 feet long
- Filter was installed on a by-pass loop in the pump discharge, downstream of the existing 127 micron service water strainer
- The 127 micron strainer elements were removed at various times during the testing program to challenge the filter





LEAR





Safety is  
a way of life



# Monitoring Equipment

- Two sample panels monitored the water on the inlet and outlet of the filter
- Turbidity, pH, conductivity, dissolved oxygen and water temperature were recorded
- Bio-boxes were installed on the inlet and the outlet of the filter







# Operation

- The filter operated in the 315 l/s to 380 l/s range since this was the demand during the test period.


# Results

- Filter operated well when inlet water was below 15 PPM TSS
- The backwash system was not effective when inlet water was very high in TSS - 60 PPM
- Veliger removal > 90%
- Veligers passing thru filter all severely traumatized.


# Lessons Learned and Recommendations

- Requires large space to retrofit.
- Filter may plug requiring manual cleaning during periods of high solids content. – by-pass recommended
- Analyze your silt load and particle size
- Particle size may change with change in TSS


## Typical Low Solids Loading Particle Size Distribution (TSS = 4.5 mg/L)



## Typical Intermediate Solids Loading Particle Size Distribution (TSS = 13.5 mg/L)



## Typical High Solids Loading Particle Size Distribution (TSS = 57 mg/L)



# Test of Ultra Violet (UV)



# Test of Ultra Violet (UV)

- Installed in Bruce 5-8 CSW
- 760 l/s (12000 usgpm)
- 20 medium pressure lamps
- manufacturer - Elsag-Bailey (now Trojan)
- Start-up: December 6, 1999




# UV Light Evaluation

**Evaluation Pre-requisites lead to  
installation on the Common Service  
Water Sytem:**

- **Ability to Retrofit**
- **Maintain Operation - flow**
- **Accessible for Maintenance**
- **"System-size"**


# Installation & Commissioning



# Results

- **Equipment**
  - operation - lamp trips, leaks
  - maintenance - lamp failure
  - life - tube discoloration
- **Biology**
  - 85% reduction in settlement

# UV Light Bank





# Discoloured Lamp Sleeves



# Lessons Learned and Recommendations

- OM&A cost of UV is higher relative to chlorine
- At the time it was difficult to get vendors interested. Not a traditional market.
- Efficacy of 85 % may require end of season chemical treatment depending on population size of mussels and system vulnerability

# Intermittent Ozone

- **Host Site: Bruce A Power Plant on Lake Huron**



# Intermittent Ozone


- manufacturer – Mitsubishi Electric
- 2 kg/day ozone
- 1 kg injected for 5 minutes, 2 times/day
- Design: 630 l/s (10,000 usgpm)
- In service: variable flows as low as 250 l/s but not greater than 630 l/s



# MABOS System

- This unique system allows a small ozone generator to continuously produce ozone and store the output in a silicone gel filled tower which is kept at  $-40^{\circ}\text{C}$ . Once or twice per day, the entire ozone content of the tower can be released into the service water stream.

# Ozone Addition System Layout



# **Issues Addressed for Ozone use**


- **Efficacy, Constructability and Operability**

**Plus**

- **Ozone off-gassing**
- **Compliance with discharge limits**
- **Corrosion / degradation of materials**

# Results

- Some veligers were able to settle between ozone additions,
- No veligers survived subsequent exposure to ozone resulting in 100% mortality
- Live juvenile and adult mussels in sidestream samplers became detached



**Ozone  
Treated**

**Control**

# Elastomer Degradation

- Exposure too short to assess effect
- Results from lab tests indicate some reduction in elongation and some loss of tensile strength

# Constructibility

- MABOS system was skid mounted – installation was straightforward
- Injection piping was complex so as to cater for multiple injection points

# Operability

- Little operator attention required
- Will need flow feedback with injection turn down – due to variable service water flow rates
- Injection into open inlet channels is not practical due to off-gassing.
- Off-gassing at service water drains in main power house is main draw back.




# Operating Costs

- The initial capital outlay is the largest cost factor to consider.
- Low operating costs - electricity, oxygen and minor repairs were \$14k/annum

# **Intermittent Ozone Conclusion**

- **System achieved 100% control of zebra mussels**
- **Injection must be into closed vessels or piping due to off-gassing and high concentrations needed at the injection points.**

# Lennox GS - Continuous Ozone



# Continuous Ozone


- manufacturer - Hankin Atlas Ozone
- 160 kg/day(350 lb/day) ozone
- Service water flow varies:
  - Design – 2700 l/s (43,000 usgpm)
  - Range during test – 600 l/s to 1300 l/s







# The System Layout


## Service Water Pumphouse with Ozonated Water System











# Diffuser – vertical portion



# Diffuser – section at bottom of channel



# Operation


- Ozone levels immediately after the injection in the inlet channel were 300 ppb
- Ozone levels within the piping system were between 50 – 80 ppb.

# Inlet Channel Results


- Concrete walls of the intake channel remained clean in areas exposed to the 300 ppb levels.
- Greater than 98% reduction in settlement of veligers within the piping system even at the 50 ppb level
- Efficacy =100 %, all settled mussels dead.
- Cooler cleaning has gone down dramatically.



# Bio-box



# Corrosion Coupon Panel



# **Constructability & Operability**

- **Installation of diffusers requires inlet channel to be drained.**
- **All other components can be installed with no interruption of station power.**
- **Manual process control is too labor intensive for a station with variable service water flow.**



# Ozone Off-gassing

- ✓ No difficulties at the injection channel
- ✗ Unacceptable off-gassing at some drains, sumps and tun dishes.
  - ✓ Fixes have been designed

# Ozone in Station Outfall

- ✓ Station discharge ozone-in-water levels below detection limit of sampling equipment. < 10ppb
- ✓ Live fish toxicity tests passed

# **Impact of Ozone on Materials of Construction and Elastomers**

- **No Corrosion observed on carbon steel coupons**
- **Little degradation of elastomers**

# Summary & Conclusions

- An open inlet channel can be protected from mussel settlement at 300 ppb ozone concentration ("Wall of Death")
- Mussel control in piping systems is generally very good at 50 ppb in the service water pump discharge.
- Plant equipment maintenance is lower.

# Summary & Conclusions

- Higher residuals are desirable for greater assurance of control but require more extensive off-gas management solutions.
- Off-gas management is the most significant safety concern for an ozonated water system.
- Compliance with discharge limits demonstrated
- **System still in Service!!!**